

REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
As of March 2026 (Quarterly)

Program/Project Title	Issue Details	Issue Typology	Location	LA	Date of Meeting	Concerned Agencies	Agreements Reached
1. Construction of Multi-Purpose Building, San Policarpo National High School (Covered Court)	No safety signagess or precautionary measures were observed at the project site The stage ceiling height appears lower than the standard The roofing of the adjacent building is positioned close the structure and may affect drainage flow The surface course and subbase may not be properly prepared prior to pouring The floor elevation may not be sufficient to prevent flooding during heavy rains	Design, scope, technical specifications	Brgy. San Policarpo Calbayog City	DPWH	Feb 13, 2026	DPWH	The committee will follow up with the Project Engineer regarding updates on the issues. Submit the report to the local chief Executives.
2. Construction of Road Network, Calbayog Development Project(Phase IV)	No project billboard sign was observed at the project site Safety signs and warning devices were not observed in the area No drainage system was observed in the area Minimal information is provided to the project timelines, closures, or the scope The installed island appears inadequate in length for its intended function Proper construction methodology may not have been fully observed	Design, scope, technical specifications	Brgy. West Awwang Calbayog City	LGU	Feb 13, 2026	LGU/CEO	The committee will follow up with the Project Engineer regarding updates on the issues. Submit the report to the local chief Executives.

Submitted by:

Designation/Office:

Date:

AUGUSTO L. MAGDARAOG

PMC Chairperson

May 13, 2026

Approved by:

Date:

RAYMUND C. UY

City Mayor

May 13, 2026