

REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
As of September 2026 (3rd Quarter)

Program/Project Title	Issue Details	Issue Typology	Location	IA	Date of Meeting	Concerned Agencies	Agreements Reached
Construction of Covered Court (Phase I)	Site entrance is narrow, with no apparent separate exit point Project billboard does not contain complete required information The location of the billboard at the back of the project limits its visibility to the public and other stakeholders The incomplete project information may affect transparency and public access to basic information Several long materials are laid across portions of the court/ work area may obstruct	Performance of Contractors/Consultants	Brgy Malopalo, Tinambacan District, Calbayog City	LGU	08/24/2026	LGU/CEO	The committee agreed that the project shall continue to be monitored to ensure that implementation remain consistent with approved plans, specifications, schedule, and applicable transparency and project monitoring requirement To address the noted safety/ housekeeping observations.

Construction of Acute Crisis Intervention Center (Phase II)	Non-compliance with BP344 accessibility standards. Insufficient railings/handrails/ for PWDs. Narrow access leading to the comfort room. Incomplete information on the project billboard. Poor visibility of the project billboard due to overgrown vegetation.	Performance of Contractors/Consultants	Brgy. San Policarpo	LGU	08/24/2026	LGU/CEO	The committee agreed that the observations/ findings concerning PWD accessibility in accordance with BP 344 shall be referred to the City Engineering Office for immediate assessment and appropriate corrective measures.
 AUGUSTO L. MAGDARAOG PMC Chairperson Sept. 21, 2026  RAYMUND C. UY City Mayor Sept. 21, 2026							
Submitted by:				Approved by:			
Designation/Office:							
Date:				Date:			