


REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
As of June 16, 2026 (2nd Quarter)

Program/Project Title	Issue Details	Issue Typology	Location	IA	Date of Meeting	Concerned Agencies	Agreements Reached
PROVISION OF RENEWABLE ENERGY-BASED ELECTRIFICATION AT BRGY. 1, SAN JOSE DE BUAN, SAMAR	structural cracks on plaster surface might due to Improper mix, inadequate curing	Site Condition/Availability	Poblacion 1	LGU San Jose de Buan, Samar	6/16/2026	Implementing Agency / Contractor	The Contractor will expedite implementation while weather conditions remain favorable.
PROVISION OF RENEWABLE ENERGY-BASED ELECTRIFICATION AT BRGY. 2, SAN JOSE DE BUAN, SAMAR	structural cracks on plaster surface might due to Improper mix, inadequate curing	Site Condition/Availability	Poblacion 2	LGU San Jose de Buan, Samar	6/16/2026	Implementing Agency / Contractor	The Contractor will expedite implementation while weather conditions remain favorable.
Construction of 2-Barrel Box Culvert at So. Manangday, Poblacion 1	Existing road right-of-way narrower than design requirements and There's a differential settlement of the culvert structure and scouring of soil around the project site.	Site Condition/Availability	Poblacion 1	LGU San Jose de Buan, Samar	6/16/2026	Implementing Agency / Contractor	The Contractor will expedite implementation while weather conditions remain favorable.

Submitted by:	 CONCEPCION M. GORDO	Approved by:	 HON. CHRISTAL JEAN R. ELIZALDE
Designation/Office:	San Jose de Buan PMC Chairperson		Municipal Mayor
Date:	16-Jun-26	Date:	16-Jun-26