


REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
As of July 2026 (Quarterly)

Program/Project Title	Issue Details	Issue Typology	Location	IA	Date of Meeting	Concerned Agencies	Agreements Reached
Const. of Multi Purpose Building	No PPEs used by the laborers/No safety gears, and No billboard. For structure , issues on footing foundation in the other side due to swampy area	Site Condition/Availability	Brgy. Basud, Sto. Niño	Municipality of Sto. Niño	July 8, 2026	Contractor, LPMC	Informed the contractor and by July 13, PPEs, safety gears and billboards be provided.
Const. of Multi Purpose Building(Bgry. Takut) Phase 1	Inspection revealed that several reinforced concrete members have exposed rebars resulting from concrete deterioration. Considering the structure's location in a coastal environment, the exposed reinforcing steel has been subjected to chloride attack from seawater, leading to corrosion and necessitating immediate rehabilitation to prevent further structural degradation.	Site Condition/Availability	Brgy. Takut, Sto. Niño	Municipality of Sto. Niño	July 8, 2026	Contractor, LPMC	Lobby to the MLGU and Barangay Council for the prioritization of the funding.

Submitted by:	 GLORIA P. SALVADOR	Approved by:	 HON. MARINELL A. APOLONIO
Designation/Office:	LPMC Chairperson		Municipal Mayor
Date:	July 8, 2026	Date:	July 8, 2026