


REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMS)
 PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
 As of June, 2026

Program/Project Title	Issue Details	Issue Typology	Location	IA	Date of Meeting	Concerned Agencies	Agreements Reached
Construction of Municipal Hall cum Evacuation Center	- No electrical outlets provided in all pantry areas. - Installed stair railing is not stainless steel.	Performance of Contractors/Consultants	Brgy. Himatagon, Saint Bernard, Southern Leyte	Municipality of Saint Bernard, Southern Leyte	June 29, 2026	MEO	Findings and recommendations will be discussed with the contractor and the implementing office.
Rehabilitaion / Improvement of level III water System Phase II	- Safety risk due to absence of ladder handle. - Overflow outlet is unprotected. - Insufficient water supply may affect service reliability.	Force Majeure	Brgy. Catmon, Saint Bernard, Southern Leyte	Municipality of Saint Bernard, Southern Leyte	June 29, 2026	MEO	Deficiencies were documented and will be relayed to the implementing office for appropriate corrective action.
Construction/ Improvement of School Building (Phase III)	Absence of safety signage may endanger workers, students, and the public.		Brgy. Tambis 2, Saint Bernard, Southern Leyte	Municipality of Saint Bernard, Southern Leyte	June 29, 2026	MEO	Contractor will be informed of the observed deficiency during the site inspection.
  							
Prepared by:	ENGR. CEILITO S. BULAGSAC	Submitted by:	DANILO A. BACUS	Approved by:	JOCelyn LIM-BUNGCARAS		
Designation/Office:	MPDC-Designate	Designation/Office:	Acting LPMO Chairperson		Municipal Mayor		
Date:		Date:		Date:			