

**REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROBLEM-SOLVING SESSION/FACILITATION MEETING CONDUCTED**

As of September 25, 2026 (3rd Quarter)

Name of Project/Issues	Location	Implementing	Date of PSS/ Facilitation Meeting	Concerned	Agreements	Next Steps
Expansion of Multi-Purpose Building	Brgy. Banday, Tomas Oppus, So. Leyte	LGU	September 15, 2026	Workers were observed working at an elevated area without wearing appropriate safety harnesses and other required Personal Protective Equipment (PPE), particularly fall-arrest equipment.	The contractor should strictly require all workers performing elevated work to wear appropriate PPE, including safety harnesses with proper anchorage/ lifelines, safety helmets, safety shoes, and other applicable protective equipment. Work at height should not proceed without adequate fall-protection measures.	PMC recommends that the Project Contractor immediately strengthen the implementation of occupational health and safety measures at the project site.
Improvement of Felicity Dream Square (Materials) / Labor by Admin.	Brgy. Banday and Bogo, Tomas Oppus, So. Leyte	LGU	September 15, 2026	No designated parking space was observed within the perimeter of the Felicity Dream Square. This may cause inconvenience to visitors and may result in improper or congested parking, particularly during events and peak periods.	Additional solar lights were already included in project plans	Implementation of project
Improvement of Felicity Dream Square (Materials) / Labor by Admin.	Brgy. Banday and Bogo, Tomas Oppus, So. Leyte	LGU	September 15, 2026	Solar lights need improvement in lighting conditions.	It is recommended to install sufficient solar-powered lighting fixtures at strategic locations within the Felicity Dream Square, particularly along walkways, entrances, activity areas, and other areas requiring illumination. The solar lights should be properly positioned and securely installed to provide adequate nighttime visibility and improve safety and security.	Implementation of project
Completion of Multi-Purpose and Livelihood Training Center	Brgy. Servanda, Tinago, Tomas Oppus, So. Leyte	LGU	September 15, 2026	Eight (8) coconut trees were observed beside the constructed covered court. Their location may pose a potential risk of damage to the covered court during strong winds, typhoons, or other severe weather conditions.	It is recommended that the concerned office/contractor assess and evaluate the condition and location of the eight (8) coconut trees. If removal is deemed necessary for public safety and protection of the covered court, proper clearing/cutting should be undertaken in accordance with applicable environmental regulations and with the necessary permits/authority. Consider	The proposed clearing of the coconut trees should undergo proper assessment and regulatory compliance, while the seawall construction should strictly conform to the approved engineering plans, specifications, and applicable standards.

Name of Project/Issues	Location	Implementing	Date of PSS/ Facilitation Meeting	Concerned	Agreements	Next Steps
					replanting suitable trees in a safe and appropriate location, when applicable.	
Completion of Multi-Purpose and Livelihood Training Center	Brgy. Servanda, Tinago, Tomas Oppus, So. Leyte	LGU	September 15, 2026	Construction of a seawall was observed/identified as necessary to protect the area from coastal erosion, storm surge, and possible damage during strong weather conditions.	It is recommended that the construction of the seawall be properly implemented based on the approved plans, specifications, and engineering design. Proper materials, foundation, alignment, drainage, and structural reinforcement should be ensured. Regular monitoring and inspection should also be conducted to ensure the seawall's durability and effectiveness in protecting the area.	Implementation of project

Prepared by:


EDMAR T. TAMBIS
PMC Secretariat

Approved by:


DANILO F. GUMANIT
PMC Chairman

Noted by:


ROD IVAN CUARES PANO
Municipal Mayor