

REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROJECT INSPECTION REPORT
 As of March 19, 2026

PMC: La Paz, Leyte

<i>Name of Project/ Program Components</i>	<i>Location</i>	<i>Implementing Agency</i>	<i>Date of Project Inspection</i>	<i>Major Findings</i>	<i>Issues</i>	<i>Action Taken/ Recommendations</i>
Construction of Reservoir (PAWA)	Barangay Pawa, La Paz Leyte	LGU	March 19, 2026	Project Completed	*The project billboard does not conform to the required size specifications *The foundation drawing in the approved plan differs from the actual finished project *The manhole handle should be stainless steel, however, the installed handle is visibly rusty * The plan requires two gate bulbs, but only one was observed on site * The reservoir roof is not sloped or pitched as required to facilitate efficient water runoff	*Informed the MEO of the findings and results of the said project.

Submitted by:
 Designation/ Office:
 Date:


ARVIN G. TERADO
 PMC Chairman

Noted by:


JOEL C. CINCO
 Agency Head

Note: This is a new form based on the existing RPMES forms Adopted in 2015.