






REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
As of March 2026 (1st Quarter)

Program/Project Title	Issue Details	Issue Typology	Location	IA	Date of Meeting	Concerned Agencies	Agreements Reached
Concreting of Local Access Road to Sanitary Land Fill	- Minimal hairline cracks detected in isolated sections. - Shoulders in some areas are loosely compacted. - No visible or insufficiently provided weakened plane (control) joints along certain stretches of the concrete pavement.	Others	Barangay Burabod, MacArthur, Leyte	LGU MacArthur	March 11, 2026	MEO & MPMC	- The Municipal Engineering Office to cause the contractor to comply and rectify the noted findings identified during the project inspection. Hence the project is still under 1 year defect liability period.

Submitted by:	 EnP Joel L. Villacorte	Approved by:	 Hon. Jonathan T. Bargin	Noted by:	 Hon. Rudin T. Babante
Designation/Office:	LPMC Secretariat		LPMC Chairman		Municipal Mayor
Date:	March 18, 2026	Date:	March 18, 2026	Date:	March 18, 2026