


**REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMS)
PROBLEM SOLVING SESSIONS/FACILITATION MEETING CONDUCTED
As of March 2026**

Program/Project Title	Issue Details	Issue Typology	Location	IA	Date of Meeting	Concerned Agencies	Agreements Reached
Rehabilitation/ improvement of Health Station at Brgy. Lawaan	Molds in the ceiling may cause deterioration of materials and may eventually ruin the ceiling over time	Performance of Contractors	Brgy. Lawaan	MEO-Municipality og San Roque, N. Samar	March 12, 2026	LPMC, MEO	Closely monitor the action of contractors
Improvement of Multi-Purpose Hall at Barangay Pagsang-an	Improper connection between the column and truss can lead to inefficient load transfer, structural instability, excessive movement, and potential failure of the structure, posing serious safety risks.	Performance of Contractors	Brgy. Pagsang-an	MEO-Municipality og San Roque, N. Samar	March 12, 2026	LPMC, MEO	Closely monitor the action of contractors

Submitted by:	 ETHEL O. RAMIREZ	Approved by:	 MARIA ANA G. ABALON, MD, MPH
Designation/Office:	LPMC-Chairman	Designation:	Local Chief Executive
Date:	March 12, 2026	Date:	March 12, 2026