

REGIONAL PROJECT MONITORING AND EVALUATION SYSTEM (RPMES)
KEY LESSONS LEARNED FROM ISSUES RESOLVED AND BEST PRACTICES
In 2026

Program/Project Title	Location	Implementing Agency	Problem/ Issue		Strategies/Actions Taken to Resolve the Problem/Issue	Responsible Entity/Key Actors and their Specific Assistance	Lessons learned and Good Practices that could be shared to the NPMC/Other PMCs
			Nature	Details			
Rehabilitation/ Improvement of Level II Water Supply System at Brgy. Libertad	Brgy. Libertad, Victoria, Northern Samar	LGU Victoria	Current	- Reservoir cover is temporary and does not provide adequate protection against contamination and unauthorized access -Exposed pipes are vulnerable to physical damage and may affect the realiability of the wayter supply system	Install concrete cover Bury and secure the pipes	Contractor/ Regular supervision of Engineering Office	None
Construction of Child Development Center “Bulilit Center”	Brgy. Lungib, Victoria, Northern Samar	LGU Victoria	Current	The project is being implemented in accordance with the approved plan. However, it was observed that the back door lacks exterior safety railings. Considering the steep pathway outside the door, this condition poses a potential safety risk to users	Install railing outside and provide slope protection on steep pathway	Contractor/Engineering Office provides technical assistance	None

Submitted by:	 EDITO E. CABACANG	Approved by:	 JOEY U. ARDALES
Designation/Office:	LPMC Chairman/SB Member		Municipal Mayor
Date:	June 30, 2026	Date:	June 30, 2026